



# Bainbridge Island Fire Department

## Memo

July 5, 2017

TO: Heather Beckmann, Planning Department

FR: Assistant Chief Luke Carpenter, Fire Marshal

RE: Winslow Hotel

PLN50880PRE

The submittal has been reviewed resulting in the following comments:

1. The project shall comply with all applicable provisions of the adopted Fire Code.
2. Fire sprinklers and alarms will be required for the project.
3. Fire flow of 1500 gpm is required.
4. Buildings over 30 feet high will require aerial apparatus access of not less than 16 feet drivable width.