



MEMO

Date: January 8, 2019
To: Olivia Sontag, Planning Department
From: Eric Dieffenbach, Deputy Fire Marshal
Re: Winslow Hotel CUP PLN50880CUP

The submittal has been reviewed resulting in the following comments:

1. The project shall comply with all applicable provisions of the adopted Fire Code.
2. Fire sprinklers and alarms will be required for the project.
3. Fire flow of 1500 gpm is required. Additional on-site hydrants may be required.
4. Buildings over 30 feet high will require aerial apparatus access of not less than 20 feet drivable width.