



# Bainbridge Island Fire Department

## Memo

City of Bainbridge Island

February 24, 2017

APR 20 2017

TO: Heather Beckmann, Planning Department

Planning and  
Community Development

FR: Assistant Chief Luke Carpenter, Fire Marshal

RE: Blakely Elementary

PLN50767PRE

The submittal has been reviewed resulting in the following comments:

1. The project shall comply with all applicable provisions of the adopted Fire Code.
2. Fire flow is required for the project and shall be not less than 1500 gpm. Fire flow shall be demonstrated to the satisfaction of the Fire Marshal.
3. Current fire flow shall be maintained to the existing school until demolition.
4. Proposed location of FDC is acceptable at this time. Final location to be approved by the Fire Marshal.
5. Proposed fire apparatus access roads and hydrant locations appear acceptable at this time.
6. A three foot clearance shall be maintained around all fire department appliances and a clear access shall be maintained.