



---

## MEMO

**Date:** September 25, 2018  
**To:** Olivia Sontag, Planning Department  
**From:** Deputy Chief Jared Moravec, Fire Marshal  
**Re:** Ericksen Townhomes PLN50804B SPR

The submittal has been reviewed resulting in the following comments:

1. The proposed project shall comply with all provisions of the adopted Fire Code.
2. The installation of residential fire sprinklers is highly recommended.
3. Fire flow is met through existing hydrants.
4. New access road will require a new road name and for home to be addressed off of new road name.