



Bainbridge Island Fire Department

Memo

April 3, 2017

TO: Kelly Tayara, Planning Department

FR: Assistant Chief Luke Carpenter, Fire Marshal

RE: Madison Grove

PLN50667SUB

The submittal has been reviewed resulting in the following comments:

1. The proposed project shall comply with all provisions of the adopted Fire Code.
2. The proposed location of the fire hydrant appears acceptable at this time.
3. A fire flow test will be required prior to the issuance of any building permits. The flow test shall be conducted during a period of ordinary demand. Contact the Fire Marshal's office at 206-451-2033 for scheduling.