

CITY OF BAINBRIDGE ISLAND  
DEPARTMENT OF PLANNING AND COMMUNITY DEVELOPMENT  
280 MADISON AVENUE NORTH · BAINBRIDGE ISLAND, WA · 98110-1812  
PHONE: (206) 842-2552 · FAX: (206) 780-0955 Web Site: www.ci.bainbridge-isl.wa.us

9/4  
Eagle Harbor  
Congregational Church  
BLD 13641 TEN-C

**LETTER OF TRANSMITTAL**

**Fire Review**

**Project Name:** EAGLE HBR CONGRETIION CHURCH  
**Date Material Received:** 9/3/2008  
**Project Number:** PRJ-0013641  
**Case Number:** BLD13641TEN-C  
**Parcel Number:** 27250241152008  
**Site address:** 105 Winslow Way W  
**Case Description:** EAGLE HARBOR CONGRATIONAL CHURCH. Tenant Improvement for partial reconfiguration of existing alter platform and addition of new clerestory window. Area of work, approx 336 sq. ft.

**Owner, Applicant & City Planner:**

**Owner**  
EAGLE HARBOR CONGRATIONAL CHURCH  
105 Winslow Way W  
Bainbridge Island, WA 98110

**Documents Distributed:**

**Comments Due By:**

**Date Sent:**


09/03/2008

**Comments:** Please select one of the following options and return to planning.

☐ No Comment

☒ See Attached Conditions / Comments

Signed:

 FIRE MARSHAL

Date:

10/10/2008

Printed:

JONED MORAVIC


CITY OF  
BAINBRIDGE ISLAND  
OCT 10 2008  
DEPT OF PLANNING &  
COMMUNITY DEVELOPMENT  
TM  
File

# Bainbridge Island Fire Department

## Memo

October 10<sup>th</sup>, 2008

TO: Mark Hinkley, Building Official

FR: Jared Moravec, Fire Marshal 

RE: Eagle Harbor Congregational Church

#BLD13641TEN-C

The plans submitted have been reviewed resulting in the following comments:

1. The remainder of the facility is required to be fire sprinkled. Plans shall be submitted to the Building Department for Fire Department.
2. All existing/outstanding fire code violations and/or concerns shall be resolved prior to a certificate of occupancy being issued.
3. A Certificate of Occupancy inspection by the Fire Department is required for this tenant finish. 48 hour notice is required.
4. Project shall comply with all applicable requirements of the 2006 International Fire Code, related City Ordinances, and Fire Department requirements.

To schedule a Fire Department inspection related to this project call Fire Marshal Jared Moravec at 206.842.7686.